



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

04/13/16

Gary Sisk
Ashland School District #5/Maintenance Dept.
885 Siskiyou Blvd.
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Ashland High School

Order No.: 1604280

Dear Gary Sisk:

Neilson Research Corporation received 5 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Ashland School District #5/Maintenance De
Project: Ashland High School
Lab Order: 1604280

Date: 13-Apr-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604280**
NRC Sample ID: **1604280-01A**
Collection Date: **04/07/16 6:41:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:40:51 PM**

Ashland High School

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Stadium Outside DF
Sample Location:
Collectors Name: Bob Cyr

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00620		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604280**
NRC Sample ID: **1604280-02A**
Collection Date: **04/07/16 6:22:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:40:51 PM**

Ashland High School

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Break Room Sink Office
Sample Location:
Collectors Name: Bob Cyr

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00113		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604280**
NRC Sample ID: **1604280-03A**
Collection Date: **04/07/16 6:26:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:40:51 PM**

Ashland High School

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Science Break Rm Sink
Sample Location:
Collectors Name: Bob Cyr

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.000398		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604280**
NRC Sample ID: **1604280-04A**
Collection Date: **04/07/16 6:34:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:40:51 PM**

Ashland High School

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: English Boys RR Sink
Sample Location:
Collectors Name: Bob Cyr

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00126		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604280**
NRC Sample ID: **1604280-05A**
Collection Date: **04/07/16 6:30:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 4:40:51 PM**

Ashland High School

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Ind. Arts D. Fountain Hall
Sample Location:
Collectors Name: Bob Cyr

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.000426		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De
Work Order: 1604280
Project: Ashland High School

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_DW

Sample ID: MB-34932	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288456						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID: LCS-34932	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288457						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09833 0.000100 0.1 0 98.3 85 115

Sample ID: 1604282-03AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288480						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09705 0.000100 0.1 0.000388 96.7 70 130

Sample ID: 1604282-03AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288481						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09628 0.000100 0.1 0.000388 95.9 70 130 0.09705 0.797 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Neilson
RESEARCH
CORPORATION
Environmental Testing Laboratory
245 South Grape Street • Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Ogishland School District
 Address: 885 SE Kiyuna Blvd.
Ashland High School
 Email: gary.sisk@ogishland.k12.or.us
 Phone: 541-461-4611 ext. 249
 Collected By (Print): Bob Carr
 Collected By (Sign): [Signature]
 Email Report: Yes No
 Fax Report: Yes No

Section B Required Project Information

Project Name: Ashland High School
 Project Number: 5
 Report To: Gary Sisk
 Copy To: Gary Sisk
 P.O. #: 164403

Section C Invoice Information

Attention: Gary Sisk
 Company Name: Ogishland Schools
 Address: 885 SE Kiyuna Blvd.

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other: _____
 Authorized: Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested			
						Lead			
Stadium Outside Drink	DW	DW	4-7-16	6:49	1				
Break Rm. Sink	DW	DW	4-7-16	6:22	1				
Science Break Rm. Sink	DW	DW	4-7-16	6:26	1				
English Boys Rm. Sink	DW	DW	4-7-16	6:34	1				
End Arts Mountain Hall	DW	DW	4-7-16	6:38	1				

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	Robert C. R. Jr	4/7/16	8:45
Received By: <u>[Signature]</u>	<u>[Signature]</u>	Gary Sisk	4-7-16	8:46
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	Gary Sisk	4-7-16	10:23
Received By: _____	_____	_____	_____	_____
Relinquished By: _____	_____	_____	_____	_____
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	Crystal Lewis	4-7-16	10:20

Section G Lab Use Only

Temp: _____
 4°C 2°C Yes No
 Received on ice: Yes No
 Number of Batches Received: _____
 pH Checked: _____
 COC Seal Intact: Yes No
 Field/Blank Included: Yes No

Received Via: UPS FedEx Other Hand
 Payment: Invoice Cash VISA/MC Check # _____ Amount: _____

Ogishland High School