



# NEILSON RESEARCH CORPORATION

*Environmental Testing Laboratory*

04/13/16

Gary Sisk  
Ashland School District #5/Maintenance Dept.  
885 Siskiyou Blvd.  
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Ashland Middle School

Order No.: 1604278

Dear Gary Sisk:

Neilson Research Corporation received 4 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Alec C Smith  
Project Manager

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**CLIENT:** Ashland School District #5/Maintenance De  
**Project:** Ashland Middle School  
**Lab Order:** 1604278

**Date:** 13-Apr-16

## CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

### Ashland School District #5/Maintenance

885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604278**

NRC Sample ID: **1604278-01A**

Collection Date: **04/07/16 6:26:00 AM**

Received Date: **04/07/16 10:20:00 AM**

Reported Date: **04/13/16 4:39:04 PM**

### Ashland Middle School

PWS ID#:

Client Sample ID: New Bldg Storage DF

Source ID:

Sample Location:

Sample Comp:

Collectors Name: Jared Gary

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	<b>0.000240</b>		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Ashland School District #5/Maintenance**  
885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604278**  
NRC Sample ID: **1604278-02A**  
Collection Date: **04/07/16 6:16:00 AM**  
Received Date: **04/07/16 10:20:00 AM**  
Reported Date: **04/13/16 4:39:04 PM**

### Ashland Middle School

PWS ID#:  
Source ID:  
Sample Comp:

Client Sample ID: Old Bldg Upper Hall DF  
Sample Location:  
Collectors Name: Jared Gary

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.000256		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Ashland School District #5/Maintenance**  
885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604278**  
NRC Sample ID: **1604278-03A**  
Collection Date: **04/07/16 6:19:00 AM**  
Received Date: **04/07/16 10:20:00 AM**  
Reported Date: **04/13/16 4:39:04 PM**

### Ashland Middle School

PWS ID#:  
Source ID:  
Sample Comp:

Client Sample ID: JM Hall DF  
Sample Location:  
Collectors Name: Jared Gary

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	ND		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Ashland School District #5/Maintenance**  
885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604278**  
NRC Sample ID: **1604278-04A**  
Collection Date: **04/07/16 6:23:00 AM**  
Received Date: **04/07/16 10:20:00 AM**  
Reported Date: **04/13/16 4:39:04 PM**

### Ashland Middle School

PWS ID#:  
Source ID:  
Sample Comp:

Client Sample ID: Kitchen Sink S Wall  
Sample Location:  
Collectors Name: Jared Gary

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00166		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De  
 Work Order: 1604278  
 Project: Ashland Middle School

**ANALYTICAL QC SUMMARY REPORT**

TestCode: ICPMS\_200.8\_DW

Sample ID: <b>MB-34932</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288456</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID: <b>LCS-34932</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288457</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09833 0.000100 0.1 0 98.3 85 115

Sample ID: <b>1604282-03AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288480</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09705 0.000100 0.1 0.000388 96.7 70 130

Sample ID: <b>1604282-03AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288481</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09628 0.000100 0.1 0.000388 95.9 70 130 0.09705 0.797 20

**Qualifiers:** E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory  
 245 South Grape Street \* Medford, OR 97501  
 (541) 770-5678 fax: (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>		<b>Section D</b>	
Required Client Information		Required Project Information		Invoice Information		Rush Status (Subject to Scheduling)	
Company:	Ashland School Dist	Project Name:	Adelphi Middle School	Attention:	GARY SISK	<input checked="" type="checkbox"/> Standard 10-14 Days <input type="checkbox"/> 5 Business Days (50% surcharge) <input type="checkbox"/> 3 Business Days (75% surcharge) <input type="checkbox"/> 24 - 48 hours (100% surcharge)	
Address:	805 Siskiyew Blvd	Project Number:	4	Company Name:	Ashland School		
	Ashland Middle School	Report To:	GARY SISK	Address:	805 Siskiyew Blvd		
Email:	gary.sisk@ashland.k12.or.us	Copy To:	GARY SISK	P.O. #	104403		
Phone:	541-761-1080						
Collected By (Print):	Sandra Gary						
Collected By (Sign):	<i>Sandra Gary</i>						
Email Report:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Fax Report:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested		NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
New Buildings Stage drunk		DW	4-7-16	10:26	1	Lead		1004278	01
Old Building upper hall DR.		DW	4-7-16	6:16	1				02
JEM. Hall drinker		DW	4-7-16	6:19	1				03
KITCHEN sink S. Wall		DW	4-7-16	6:23	1				04

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

<b>Section F</b>		<b>Section G</b>	
Relinquish/Receive		Lab Use Only	
Relinquished By:	<i>April T. Perry</i>	Temp:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Received By:	<i>Gary Sisk</i>	4°C +/- 2°C:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Relinquished By:	<i>Gary Sisk</i>	Received on/ice:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Received By:	<i>Gary Sisk</i>	Number of Bottles Received:	
Relinquished By:	<i>Crystal Lewis</i>	Field Blank Included:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Received By Laboratory:	<i>Crystal Lewis</i>	Field Blank Included:	Yes <input type="checkbox"/> No <input type="checkbox"/>

Ashland Middle School  
 100 Walker Ave

Payment:	Invoice	Cash	VISA/MC	Check #	Amount