



# NEILSON RESEARCH CORPORATION

*Environmental Testing Laboratory*

04/13/16

Gary Sisk  
Ashland School District #5/Maintenance Dept.  
885 Siskiyou Blvd.  
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Lincoln School

Order No.: 1604282

Dear Gary Sisk:

Neilson Research Corporation received 3 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Alec C Smith  
Project Manager

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**CLIENT:** Ashland School District #5/Maintenance De  
**Project:** Lincoln School  
**Lab Order:** 1604282

**Date:** 13-Apr-16

## CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Ashland School District #5/Maintenance**  
885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604282**  
NRC Sample ID: **1604282-01A**  
Collection Date: **04/07/16 5:18:00 AM**  
Received Date: **04/07/16 10:20:00 AM**  
Reported Date: **04/13/16 4:43:07 PM**

## Lincoln School

PWS ID#:  
Source ID:  
Sample Comp:

Client Sample ID: Mont. Kitchen  
Sample Location:  
Collectors Name: Gary Sisk

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00283		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

### Ashland School District #5/Maintenance

885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604282**

NRC Sample ID: **1604282-02A**

Collection Date: **04/07/16 5:21:00 AM**

Received Date: **04/07/16 10:20:00 AM**

Reported Date: **04/13/16 4:43:07 PM**

### Lincoln School

PWS ID#:

Client Sample ID: Room 4 Sink

Source ID:

Sample Location:

Sample Comp:

Collectors Name: Gary Sisk

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	<b>0.000194</b>		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**Ashland School District #5/Maintenance**  
885 Siskiyou Blvd.  
Ashland, OR 97520

Lab Order: **1604282**  
NRC Sample ID: **1604282-03A**  
Collection Date: **04/07/16 5:20:00 AM**  
Received Date: **04/07/16 10:20:00 AM**  
Reported Date: **04/13/16 4:43:07 PM**

## Lincoln School

PWS ID#:  
Source ID:  
Sample Comp:

Client Sample ID: Drinking Fountain Hall  
Sample Location:  
Collectors Name: Gary Sisk

## ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.000388		0.0001	mg/L	0.015 A	04/12/16	BAR

**Notes:** ND - Not Detected at the MRL  
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De  
 Work Order: 1604282  
 Project: Lincoln School

**ANALYTICAL QC SUMMARY REPORT**

TestCode: ICPMS\_200.8\_DW

Sample ID: <b>MB-34932</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288456</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID: <b>LCS-34932</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288457</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09833 0.000100 0.1 0 98.3 85 115

Sample ID: <b>1604282-03AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>Drinking Fountain H</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288480</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09705 0.000100 0.1 0.000388 96.7 70 130

Sample ID: <b>1604282-03AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>04/11/16</b>	RunNo: <b>86393</b>						
Client ID: <b>Drinking Fountain H</b>	Batch ID: <b>34932</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>04/12/16</b>	SeqNo: <b>1288481</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09628 0.000100 0.1 0.000388 95.9 70 130 0.09705 0.797 20

**Qualifiers:** E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

