



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

04/13/16

Gary Sisk
Ashland School District #5/Maintenance Dept.
885 Siskiyou Blvd.
Ashland, OR 97520

TEL: (541) 601-6680

FAX: (541) 488-6102

RE: Walker Elementary

Order No.: 1604260

Dear Gary Sisk:

Neilson Research Corporation received 3 sample(s) on 04/07/16 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Ashland School District #5/Maintenance De
Project: Walker Elementary
Lab Order: 1604260

Date: 13-Apr-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604260**
NRC Sample ID: **1604260-01A**
Collection Date: **04/07/16 5:15:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 3:12:44 PM**

Walker Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Kitchen Veg Sink
Sample Location:
Collectors Name: Lisa March

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00156		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604260**
NRC Sample ID: **1604260-02A**
Collection Date: **04/07/16 5:15:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 3:12:44 PM**

Walker Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Fountain Main Hall
Sample Location:
Collectors Name: Lisa March

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00274		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Ashland School District #5/Maintenance
885 Siskiyou Blvd.
Ashland, OR 97520

Lab Order: **1604260**
NRC Sample ID: **1604260-03A**
Collection Date: **04/07/16 5:15:00 AM**
Received Date: **04/07/16 10:20:00 AM**
Reported Date: **04/13/16 3:12:44 PM**

Walker Elementary

PWS ID#:
Source ID:
Sample Comp:

Client Sample ID: Gym Fountain
Sample Location:
Collectors Name: Lisa March

ANALYTICAL RESULTS

Analyses	Code	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	1030	EPA 200.8	A	0.00600		0.0001	mg/L	0.015 A	04/12/16	BAR

Notes: ND - Not Detected at the MRL
MDL = Method Detection Limit

N.L. = No Limit

CLIENT: Ashland School District #5/Maintenance De
Work Order: 1604260
Project: Walker Elementary

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_DW

Sample ID: MB-34932	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288456						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID: LCS-34932	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288457						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09833 0.000100 0.1 0 98.3 85 115

Sample ID: 1604282-03AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288480						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09705 0.000100 0.1 0.000388 96.7 70 130

Sample ID: 1604282-03AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 04/11/16	RunNo: 86393						
Client ID: ZZZZZ	Batch ID: 34932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 04/12/16	SeqNo: 1288481						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09628 0.000100 0.1 0.000388 95.9 70 130 0.09705 0.797 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

